Transylvania County Health Department Certificate Of Approval

The sewerage disposal system described on the record below has been inspected and approved by an agent of the Transylvania County Health Department.

Condominium #2 Jack McGinnis, R.S. Signed
Jack Dupont Co. - Builder

Sewage Disposal Record

Occupant Condominium #2 Owner

Location of Building Robin Hill (Former Malta Property), Lake

Address Toxaway Country Club Sect., Lake Toxaway, N.C.

Contractor Spaulding Allison Address Horse Shoe, N.C.

Date of Inspection 9-18-73 No. of Bedrooms (4) 2 Bedroom Apartments Baths No. of Users

Septic Tank Materials: Concrete Block (Size ____ in.) ☐ Poured Concrete ☐ Pre-Cast ☒

Capacity (2) 1100 (liquid) Gals. Single or Double Compartment ☒

Adequate For: Garbage Grinder ☒ Yes ☐ No

Nitrification Field Materials: Terra Cotta ☐ Concrete ☐ Perforated Plastic ☒

for 2 Septic Tanks

Distribution Box Yes No. of Lines ____ Width ____ Length of Lines ____

Stone ____ Other ____ (See Sketch below)

Adequate For: Washing Machine ☐ Yes ☒ No (Not plumbed for auto machine).

Sand Filter No. of Lines ____ Width of Line ____ Length of Line ____ Approved Sand ____

Precolation Test ☐ Yes ☒ No

Sketch of System

