



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
Phone: 978-391-4428 | website: www.nashobaanalytical.com

Laboratory Report

Cool Water Pump Co.
2643 West St
Wrentham, MA 02093

Date Printed: 04/09/2024
Work Order #: 2404-00337
Client Job #:
Date Received: 04/02/2024
Sample collected in: Massachusetts

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: H = Hold time non-compliant.**

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Erin Shaw
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/09/2024
CLIENT NAME: Cool Water Pump Co.
CLIENT ADDRESS: 2643 West St
Wrentham, MA 02093

SAMPLE ID #: 2404-00337-001
SAMPLED BY: Jones, Bob

SAMPLE ADDRESS: Sara Winthrop
1563 Bay Rd
Sharon MA

MORE LOC INFO: Kitchen Sink

Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

DATE AND TIME COLLECTED: 04/02/2024 08:30AM
DATE AND TIME RECEIVED: 04/02/2024 11:48AM
ANALYSIS PACKAGE: M-Comprehensive
RECEIPT TEMPERATURE: ON ICE 11.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Turbidity*	0.62	NTU			0.5	No Limit	EPA 180.1	AH-MA	04/02/2024 12:34PM
Calcium*	31	mg/L			1	No Limit	EPA 200.7	PF-MA	04/03/2024 03:40PM
Copper*	0.018	mg/L	✓		0.010	1.3 mg/L	EPA 200.7	PF-MA	04/03/2024 03:40PM
Iron*	0.043	mg/L	✓		0.010	0.3 mg/L	EPA 200.7	PF-MA	04/03/2024 03:40PM
Magnesium	2.0	mg/L			1.0	No Limit	EPA 200.7	PF-MA	04/03/2024 03:40PM
Manganese*	0.304	mg/L	⚠		0.010	0.05 mg/L	EPA 200.7	PF-MA	04/03/2024 03:40PM
Potassium	<1.0	mg/L			1.0	No Limit	EPA 200.7	PF-MA	04/03/2024 03:40PM
Sodium*	13.4	mg/L	✓		1	20 mg/L	EPA 200.7	PF-MA	04/03/2024 03:40PM
Arsenic*	<0.001	mg/L	✓		0.001	0.010 mg/L	EPA 200.8	NM-NH	04/03/2024 06:59PM
Lead*	<0.001	mg/L	✓		0.001	0.015 mg/L	EPA 200.8	NM-NH	04/03/2024 06:59PM
Chloride*	12.8	mg/L	✓		2	250 mg/L	EPA 300.0	AH-MA	04/02/2024 06:01PM
Fluoride*	2.69	mg/L	⚠		0.2	4.0 mg/L	EPA 300.0	AH-MA	04/02/2024 06:01PM
Nitrate as N*	0.20	mg/L	✓		0.05	10 mg/L	EPA 300.0	AH-MA	04/02/2024 06:01PM
Nitrite as N*	<0.05	mg/L	✓		0.05	1 mg/L	EPA 300.0	AH-MA	04/02/2024 06:01PM
Sulfate*	9.3	mg/L	✓		2	250 mg/L	EPA 300.0	AH-MA	04/02/2024 06:01PM
Sediment	Absent						N/A N/A	AH-MA	04/02/2024 12:26PM
Color, Apparent	15	CU	✓		0	15	SM 2120B	AH-MA	04/02/2024 12:33PM
Odor	0	TON	✓		0	3 T.O.N.	SM 2150B	AH-MA	04/02/2024 12:26PM
Total Alkalinity*	72	mg CaCO3/L			1	No Limit	SM 2320B	AH-MA	04/02/2024 04:50PM
Hardness (calc.)	86	mg CaCO3/L			1	No Limit	SM 2340 B	PF-MA	04/03/2024 03:40PM
Specific Conductance @ 25°C	222	umhos/cm			10	No Limit	SM 2510B	AH-MA	04/02/2024 12:38PM
Residual Free Chlorine*	<0.2	mg/L	✓	H	0.2	4	SM 4500Cl-G	AH-MA	04/02/2024 12:57PM
pH at 25°C*	6.84	SU	✓	H	N/A	6.5 - 8.5 SU	SM 4500-H-B	AH-MA	04/02/2024 12:38PM
Ammonia as N	<0.1	mg/L			0.1	No Limit	SM 4500NH3 D	AH-MA	04/08/2024 01:17PM

Total Coliform / E.coli Bacteria Preparation (Colilert®-18) 20th ED SM 9223B ES-MA 04/02/2024 01:50PM

Erin Shaw

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/09/2024
CLIENT NAME: Cool Water Pump Co.
CLIENT ADDRESS: 2643 West St
Wrentham, MA 02093

SAMPLE ID #: 2404-00337-001
SAMPLED BY: Jones, Bob

SAMPLE ADDRESS: Sara Winthrop
1563 Bay Rd
Sharon MA

MORE LOC INFO: Kitchen Sink

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

DATE AND TIME COLLECTED: 04/02/2024 08:30AM

DATE AND TIME RECEIVED: 04/02/2024 11:48AM

ANALYSIS PACKAGE: M-Comprehensive

RECEIPT TEMPERATURE: ON ICE 11.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Coliform Bacteria*	Absent	P-A/100mL	✓		Absent	No Limit	SM 9223B	ES-MA	04/03/2024 09:23AM
E. coli Bacteria*	Absent	P-A/100mL	✓		Absent	Absent	SM 9223B	ES-MA	04/03/2024 09:23AM
Total Coliform / E.coli Bacteria Preparation (Colilert®-18) 20th ED							SM 9223B	ES-MA	04/02/2024 01:50PM

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
 Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/09/2024
CLIENT NAME: Cool Water Pump Co.
CLIENT ADDRESS: 2643 West St
 Wrentham, MA 02093

SAMPLE ID #: 2404-00337-002
SAMPLED BY: Jones,Bob

SAMPLE ADDRESS: Sara Winthrop
 1563 Bay Rd
 Sharon MA

MORE LOC INFO: Kitchen Sink

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

DATE AND TIME COLLECTED: 04/02/2024 08:30AM
DATE AND TIME RECEIVED: 04/02/2024 11:48AM
ANALYSIS PACKAGE: M-VOC524.2-MA
RECEIPT TEMPERATURE: ON ICE 11.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
1,1,1,2-Tetrachloroethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,1,1-Trichloroethane*	<0.5	ug/L	✓		0.5	200 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,1,2,2-Tetrachloroethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,1,2-Trichloroethane*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,1-Dichloroethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,1-Dichloroethylene*	<0.5	ug/L	✓		0.5	7 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,1-Dichloropropylene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2,3-Trichlorobenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2,3-Trichloropropane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2,4-Trichlorobenzene*	<0.5	ug/L	✓		0.5	70 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2,4-Trimethylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2-Dibromo-3-chloropropane	<0.5	ug/L			0.5	0.2 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2-Dibromoethane	<0.5	ug/L			0.5	0.05 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2-Dichlorobenzene*	<0.5	ug/L	✓		0.5	600 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2-Dichloroethane*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2-Dichloropropane*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,3,5-Trimethylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,3-Dichlorobenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,3-Dichloropropane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,4-Dichlorobenzene*	<0.5	ug/L	✓		0.5	5.0 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
2,2-Dichloropropane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
2-Butanone (MEK)	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
2-Chlorotoluene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
2-Hexanone	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM

Erin Shaw

Erin Shaw
 Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
 Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/09/2024
CLIENT NAME: Cool Water Pump Co.
CLIENT ADDRESS: 2643 West St
 Wrentham, MA 02093
SAMPLE ID #: 2404-00337-002
SAMPLED BY: Jones, Bob
SAMPLE ADDRESS: Sara Winthrop
 1563 Bay Rd
 Sharon MA
MORE LOC INFO: Kitchen Sink

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

DATE AND TIME COLLECTED: 04/02/2024 08:30AM
DATE AND TIME RECEIVED: 04/02/2024 11:48AM
ANALYSIS PACKAGE: M-VOC524.2-MA
RECEIPT TEMPERATURE: ON ICE 11.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
4-Chlorotoluene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
4-Isopropyltoluene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
4-Methyl-2-pentanone (MIBK)	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Acetone	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Benzene*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
Bromobenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Bromochloromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Bromodichloromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Bromoform*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Bromomethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Carbon disulfide	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Carbon tetrachloride*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
Chlorobenzene*	<0.5	ug/L	✓		0.5	100 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
Chloroethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Chloroform*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Chloromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
cis-1,2-Dichloroethylene*	<0.5	ug/L	✓		0.5	70 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
cis-1,3-Dichloropropylene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Dibromochloromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Dibromomethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Dichlorodifluoromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Diethyl ether	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Diisopropyl ether (DIPE)	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Ethyl tert-butyl ether (ETBE)	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM

Erin Shaw

Erin Shaw
 Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/09/2024
CLIENT NAME: Cool Water Pump Co.
CLIENT ADDRESS: 2643 West St
Wrentham, MA 02093

SAMPLE ID #: 2404-00337-002
SAMPLED BY: Jones, Bob

SAMPLE ADDRESS: Sara Winthrop
1563 Bay Rd
Sharon MA

MORE LOC INFO: Kitchen Sink

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

DATE AND TIME COLLECTED: 04/02/2024 08:30AM
DATE AND TIME RECEIVED: 04/02/2024 11:48AM
ANALYSIS PACKAGE: M-VOC524.2-MA
RECEIPT TEMPERATURE: ON ICE 11.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Ethylbenzene*	<0.5	ug/L	✓		0.5	700 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
Hexachlorobutadiene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Isopropylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
m&p-Xylenes	<1	ug/L			1	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Methyl tert-butyl ether (MtBE)*	<0.5	ug/L	✓		0.5	70 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
Methylene chloride*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
Naphthalene*	<0.5	ug/L	✓		0.5	100 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
n-Butylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Nitrobenzene	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
n-Propylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
o-Xylene	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
sec-Butylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Styrene*	<0.5	ug/L	✓		0.5	100 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
tert-Amyl methyl ether (TAME)	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
tert-Butyl alcohol (TBA)	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
tert-Butylbenzene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Tetrachloroethylene*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
Tetrahydrofuran (THF)	<10	ug/L			10	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Toluene*	<0.5	ug/L	✓		0.5	1000 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
Total THMs*	<0.5	ug/L	✓		0.5	80 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
Total Xylenes*	<0.5	ug/L	✓		0.5	10000 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
trans-1,2-Dichloroethylene*	<0.5	ug/L	✓		0.5	100 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
trans-1,3-Dichloropropylene*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Trichloroethylene*	<0.5	ug/L	✓		0.5	5 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM

Erin Shaw

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432

Phone: 978-391-4428 | website: www.nashobaanalytical.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/09/2024
CLIENT NAME: Cool Water Pump Co.
CLIENT ADDRESS: 2643 West St
Wrentham, MA 02093

SAMPLE ID #: 2404-00337-002
SAMPLED BY: Jones, Bob

SAMPLE ADDRESS: Sara Winthrop
1563 Bay Rd
Sharon MA

MORE LOC INFO: Kitchen Sink

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

DATE AND TIME COLLECTED: 04/02/2024 08:30AM

DATE AND TIME RECEIVED: 04/02/2024 11:48AM

ANALYSIS PACKAGE: M-VOC524.2-MA

RECEIPT TEMPERATURE: ON ICE 11.9° CELSIUS

CLIENT JOB #:

Test Description	Result	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date - Time Analyzed
Trichlorofluoromethane*	<0.5	ug/L			0.5	No Limit	EPA 524.2	KV-NH	04/03/2024 10:57PM
Vinyl chloride*	<0.5	ug/L	✓		0.5	2 ug/L	EPA 524.2	KV-NH	04/03/2024 10:57PM
1,2-Dichlorobenzene-d4	96	%	✓		0.5	70-130%	EPA 524.2 - SS	KV-NH	04/03/2024 10:57PM
4-Bromofluorobenzene	90	%	✓		0.5	70-130%	EPA 524.2 - SS	KV-NH	04/03/2024 10:57PM

Erin Shaw
Laboratory Director



NASHOBA ANALYTICAL

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

31A Willow Road Ayer, Massachusetts 01432
Phone: 978-391-4428 | website: www.nashobaanalytical.com

2404-00337

Chain of Custody for Commercial Clients:

****Your company name:**** Cool Water Pump Co

SAMPLE INFORMATION - please print clearly

Project or Customer Name:	Sara Winthrop
Street Address:	1563 Bay Rd
Town and State:	Sharon MA
Date Sampled:	4-2-24
Time Sampled:	8:30 AM
Sample Taken At: (i.e Kitchen Sink, Well Head...)	Kitchen sink
Sampled by (Name):	Bob Jones

Test(s) to be Performed:	Comprehensive, VOC's
--------------------------	----------------------

(if not sure ask an analyst)

Email Results:

<u>Lab Use Only:</u>	
Receipt Temperature: 11.9 °C	Ice: <input checked="" type="checkbox"/> Y or N
Date 4/2/24	Time 11:48
Received at Lab by:	