

# PRIVATE WELL INSPECTION CHECKLIST

Graham Drilling Inc.  
PO Box 206  
Sheridan, Mt. 59749-0206  
406-842-5214

ADDRESS of Well: 107 Antelope Meadows Rd  
Owners Name and Address: Mathew & Lisa Stapp  
Well Type: Domestic  
Well Depth 194' feet Date Drilled unknown  
Well Sealed \_\_\_\_\_ Casing above ground 1'  
Well TD 194 Static Level 88.5' Gallons Per Minute 5

WELL RATING: EXCELLENT/NEW \_\_\_\_\_ GOOD X FAIR \_\_\_\_\_ BAD/FAIL \_\_\_\_\_ OTHER \_\_\_\_\_  
NOTES: \_\_\_\_\_

## PUMP SYSTEM

PRESSURE TANK: Well Troll NEW \_\_\_\_\_ GOOD X FAIR \_\_\_\_\_ BAD \_\_\_\_\_  
TANK PRESSURE: 35 RECOMMENDED PSI 35  
PRESSURE SWITCH: 40/60 NEW ✓ GOOD \_\_\_\_\_ FAIR \_\_\_\_\_ BAD \_\_\_\_\_  
CUT-IN PRESSURE 40 CUT-OUT PRESSURE 60 DIFFERENTIAL 20  
PRESSURE GAUGE: \_\_\_\_\_ NEW \_\_\_\_\_ GOOD X FAIR \_\_\_\_\_ BAD \_\_\_\_\_  
CONTROL BOX: N/A NEW \_\_\_\_\_ GOOD \_\_\_\_\_ FAIR \_\_\_\_\_ BAD \_\_\_\_\_  
WIRING/ELECTRICAL \_\_\_\_\_ NEW \_\_\_\_\_ GOOD X FAIR \_\_\_\_\_ BAD \_\_\_\_\_  
PUMP: 1/2 HP X10 AMPS 8.8 NORMAL X NEW \_\_\_\_\_ GOOD X FAIR \_\_\_\_\_ BAD \_\_\_\_\_

NOTES: MADE ALL CHANGES AS REQUESTED FROM MONTANA PUMPS.  
REPLACED HYDRANT, ABANDONED LINE, FIXED UNDERGROUND  
LEAK, ADDED HYDRANT, REPLACED PUMP IN WELL WITH  
SC# 80 DROP PIPE, REPLACED PRESSURE SWITCH + STAND PIPE

PUMP INSPECTOR: [Signature] DATE: 1/8/26  
NAME: (PRINT) RICK J. JOHNSON

STATE OF MONTANA  
DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION  
1424 9TH AVENUE P.O. BOX 201601 HELENA, MONTANA 59620-1601

## GENERAL ABSTRACT

**Water Right Number:** 41F 30020291 GROUND WATER CERTIFICATE

**Version:** 1 -- ORIGINAL RIGHT

**Version Status:** ACTIVE

**Owners:** LISA STAPP  
PO BOX 984  
ENNIS, MT 59729  
MATHEW STAPP  
PO BOX 984  
ENNIS, MT 59729

**Priority Date:** MARCH 14, 2006 at 12:49 P.M.

**Enforceable Priority Date:** MARCH 14, 2006 at 12:49 P.M.

**Purpose (Use):** DOMESTIC  
LAWN AND GARDEN

**Maximum Flow Rate:**

**Maximum Volume:** 1.63 AC-FT

**Maximum Acres:** 0.25

**Source Name:** WELL

**Source Type:** GROUNDWATER

**Point of Diversion and Means of Diversion:**

<u>ID</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1		NWSENE	5	6S	1W	MADISON

**Period of Diversion:** JANUARY 1 TO DECEMBER 31

**Diversion Means:** WELL

**Subdivision:** ANTELOPE MEADOWS NO 2 TRACT/LOT: 10-2

**Well Depth:**

**Well Location:** 137 ANTELOPE MEADOWS ROAD

**Purpose (Use):** DOMESTIC

**Households:** 1

**Volume:** 1.00 AC-FT

**Period of Use:** JANUARY 1 to DECEMBER 31

**Place of Use:**

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1			NE	5	6S	1W	MADISON

**Subdivision:** ANTELOPE MEADOWS NO 2 TRACT/LOT 10-2

**Purpose (Use):** LAWN AND GARDEN

**Volume:** 0.63 AC-FT

**Period of Use:** APRIL 1 to OCTOBER 31

**Place of Use:**

<u>ID</u>	<u>Acres</u>	<u>Govt Lot</u>	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<u>County</u>
1	0.25		NE	5	6S	1W	MADISON

**Subdivision:** ANTELOPE MEADOWS NO 2 TRACT/LOT 10-2

**Total:** 0.25

**Geocodes/Valid:** 25-0423-05-1-02-05-0000 - Y

---

**Remarks:**

**REISSUED RIGHT**

THE RIGHT ISSUED ON 04/03/2006 WAS REISSUED. THE RIGHT WAS REISSUED BECAUSE A FLOW RATE, VOLUME, AND WELL DEPTH WERE QUANTIFIED AND THE POINT OF DIVERSION LEGAL LAND DESCRIPTION WAS CORRECTED TO REFLECT THE ORIGINAL FILING.

**OWNERSHIP UPDATE RECEIVED**

OWNERSHIP UPDATE TYPE DOR # 105157 RECEIVED 08/31/2012.

OWNERSHIP UPDATE TYPE DOR # 147330 RECEIVED 08/31/2016.