

Other Options

[Return to menu](#)
[Plot this site in State Library Digital Atlas](#)
[Plot this site in Google Maps](#)

Section 7: Well Test Data

Total Depth: 140
Static Water Level: 64
Water Temperature:

Section 2: Location

Air Test *

35 gpm with drill stem set at 135 feet for 1 hours.
Time of recovery 0.5 hours.
Recovery water level 64 feet.
Pumping water level _ feet.

MADISON

Geomethod	Datum
NAV-GPS	NAD83

** During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.*

Ground Surface Altitude	Ground Surface Method	Datum	Date
-------------------------	-----------------------	-------	------

Addition

Block

Lot

Section 8: Remarks

Section 3: Proposed Use of Water

DOMESTIC (1)

Section 4: Type of Work

Drilling Method: DUAL ROTARY
Status: NEW WELL

Section 5: Well Completion Date

Date well completed: Thursday, July 7, 2022

Section 6: Well Construction Details

Borehole dimensions

From	To	Diameter
0	140	6

Casing

From	To	Diameter	Wall Thickness	Pressure Rating	Joint	Type
-2	40	6	0.25		WELDED	A53B STEEL
20	140	4		220.0	BELL	PVC-SCHED 40

Completion (Perf/Screen)

From	To	Diameter	# of Openings	Size of Openings	Description
100	140	4	40	1/8X7	SAW SLOTS

Annular Space (Seal/Grout/Packer)

From	To	Description	Cont. Fed?
0	30	#8 BENTONITE	Y

Section 9: Well Log

Geologic Source

Unassigned

[illegible]

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name: JOSH HANSON

Company: GRAHAM DRILLING INC

License No: WWC-693

Date Completed: 7/7/2022