

Certificate of Survey
SEPTIC SYSTEM SITE PLAN

LEGEND

- percolation test hole
- soil boring
- existing elevation contour
- proposed elevation contour
- existing spot elevation
- proposed spot elevation
- Elevations relative and assumed
- Elevations relative to U.S.G.S. 1929 N.G.V.D.

Notes:


- Avoid compaction of mound area before, during and after construction
- Verify before drilling that no septic tanks or septic areas are within a 50 foot radius of proposed well location. (100 feet for shallow well)
- Verify before construction that no shallow wells are within 100 feet, or deep wells within 50 feet of proposed septic tanks or mound area.
- To extend the life of septic system pump septic tanks a minimum of every 2 years.
- See attached sheets for additional construction details.
- Site plan prepared by or under the supervision of Tony Elvestad - M.P.C.A. Certification No. 1410

USING EXISTING
DRIVEWAY FROM
TO RD 6/WATERTOWN RD


LEGAL DESCRIPTION SUPPLIED BY CLIENT

That part of the East 1/2 of the West 3/8 of the East Half of the Northwest 1/4 of section 31, Township 118 North, Range 23 west of the Principal Meridian lying southerly of the Southerly right of way line of County Road 6 and lying Northwesterly of a line drawn 50 feet Northwesterly of and parallel with the following described line:

Beginning at the southwest corner of Section 31, Township 118, Range 23; thence on an assumed bearing of North 0 degrees 40 minutes 43 seconds West along the west line of the southwest Quarter of Section 31, a distance of 777.96 feet; thence Northeasterly 1313.29 feet along a tangential curve, concave to the southeast, having a radius of 1532.80 feet and a central angle of 49 degrees 05 minutes 26 seconds; thence North 48 degrees 24 minutes 43 seconds East and tangent to last described curve, 2725.85 feet and said line there terminating. All according to the United States Government Survey thereof, and situate in Hennepin County, Minnesota.



GRAPHIC SCALE



○ Denotes iron monument set
● Denotes iron monument found
Bearings based on assumed data

I hereby certify that this survey, plan or report was prepared by me or under my direct supervision and that I am a duly Registered Land Surveyor under the laws of the State of Minnesota.

Tony Elvestad 3-7-94
Tony Elvestad
Registration No. 17549

Requested by:

Jeff Broll



Westwood Professional Services, Inc.
200 Central Avenue
Buffalo, Minnesota 55313
(612) 682-2587

Book 19

page 45

Drawn by

RKR

Date:

03-03-94

Job No.

94629