

3454

Town of Fairfield – Office of the Fire Marshal
140 Reef Road, Fairfield, CT 06824 Phone (203) 254-4720 Fax (203) 254-4724

Permit Application For
REMOVAL OR ABANDONMENT OF UNDERGROUND STORAGE TANKS

NOTE: This application to be filed with the Fire Marshal's Office BEFORE performing work.

1. Address of Removal or Abandonment: 415 Old Post Road
2. Property Owner Name: John Byrne
3. Contractor's Name: Absolute Tank Removal Phone: (203) 882-9391
4. Contractor's Address: 81 Munson Street
5. Removal contractor's Home Improvement Contractor's Registration: # 564560
6. Number and sizes of tank(s) to be REMOVED 1-1,000 gal ABANDONED _____
7. Last contents of tank(s): #2 Home Heating Oil

On rear of application or on separate sheet, show location of tank(s) to be removed/abandoned in relation to building and street.

8. If tank is to be abandoned, indicate material tank is to be filled with: NA
9. Expected date work will commence: MAY 12, 2005 @ 8:00 AM.
10. Notify "Call Before You Dig" at 1-800-922-4455 at least 72 hours before starting job.
Permit Number: 2005-1702771
11. Removal or abandonment of underground petroleum tanks is regulated by the Connecticut Flammable and Combustible Liquids Code. This Code includes NFPA 30, sect. 2-4.4 which provides the requirements on how to safely remove underground storage tanks which contained flammable or combustible liquids. *It is the responsibility of the applicant and/or the actual remover to adhere to these and any other applicable local, state or federal regulations.*
12. Make and model of combustible gas indicator: Gas Tech - GT-2400
13. If tank is leaking, notify D.E.P (860-424-3338) and the Fire Marshal (203-254-4720).

14. Please supply this Office with copies of any soil tests or remediation activities.

Edward F. Marin
Applicant's Signature

4/20/05
Date

FAXED
APR 21 2005

Fire Marshal's Office Date Received: _____ By: _____
Site Visit? Y N Date: _____ By: _____
Remarks: _____

STRAIGHT BILL OF LADING/NON-HAZARDOUS WASTE MANIFEST

Nº 5774

1. Generator Information Generator Name: <u>John Bryne</u> Generator Mailing Address: <u>415 Old Post Rd Ffld, CT</u> Site Address: <u>SAME</u> Generator Telephone No.: <u>255-9737</u>		2. Destination/Disposal Facility Information Company Name: <u>United Recycling</u> Telephone No.: <u>1-800-404-4408</u> Facility Site Address: <u>50 Cross Street, Bridgeport, CT</u>	
3. Transporter Information Transporter 1 Company Name: <u>Absolute Tank Removal</u> Telephone No.: <u>203-882-9391</u> License Plate No.: <u>CT</u> Transporter 2 Company Name: Telephone No.: License Plate No.:			
4. Material/Waste Description			
Containers		Material Description/ Proper Shipping Name if DOT Hazardous Material	
No.	Type	1HM	
a. 001	TT		Fuel oil-water mix non (RCRA) liquid n.o.s.
b.			
c.			
d.			
5. Job No.	6. Approval Nos.	7. Purchase Order No.	8. Additional Information
9. Required Placard(s)			
10. Generator Certification: I hereby certify the above-named materials are properly classified, described, packaged, marked, and are in proper condition for transportation according to the applicable regulations of the Department of Transportation.			
Generator Name: <u>John Bryne</u>		Generator Signature: <u>John Bryne</u> Shipment Date: <u>5-12-05</u>	
Acknowledgement of Receipt of Material - To be Completed by Signatories			
Transporter 1 Driver Name (Print): <u>VICTOR DIAZ</u>		Signature: <u>Victor Diaz</u> Shipment Date: <u>5-12-05</u>	
Transporter 2 Driver Name (Print):		Signature: Shipment Date:	
Facility Receiving Wastes - Authorized Agent:		Signature: Receipt Date:	
Emergency Telephone No.: <u>(203) 882-9391</u>		Contact Name: <u>Edward F. Marin</u>	
Discrepancy Indication Space to be Completed by the Disposal Facility.		Required for transportation of DOT Hazardous Material only.	


This form may not be used for wastes identified as hazardous under state or RCRA regulations.

White: Retained by TSDF

Canary: Mailed by TSDF to ATR Branch

Pink: Retained by Generator

415 Old Post Rd



ABSOLUTE TANK REMOVAL, LLC

81 Munson Street, Milford, Connecticut 06460

Office (203) 882-9391

Fax (203) 882-9392

July 28, 2005

RECEIVED

AUG - 2 2005

FAIRFIELD FMO

John Byrne
415 Old Post Road
Fairfield, CT 06824

**RE: Underground Storage Tank Removal
John Byrne, 415 Old Post Road, Fairfield, CT 06824**

Dear John:

The following documentation is very important and should be saved regarding the property where this work has been performed. Items included are as follows:

- Confirmation of tank removal
- Copy of soil analysis from the tank grave performed by a state certified laboratory showing total petroleum hydrocarbons (TPH) in parts per million (PPM)
- Copy of any permits or inspections required by local or state authorities
- Copy of waste manifest for the disposal of any liquid waste or sludge removed from the tank
- Receipt for proper disposal of tank at an approved recycling facility

We have sent a copy of all pertinent documentation regarding this matter to the local authoritative agency in your jurisdiction. We hope our company has exceeded your expectations and that you are pleased with all aspects of the work performed. Should you have any questions on this matter or if we can be of any assistance in the future, please feel free to contact us.

Sincerely,
Absolute Tank Removal

Edward F. Marin
Edward F. Marin
Project Coordinator

EFM/tan

CT Licensed Spill Contractor & Hazardous Waste Transporter - CT-HW-692
HVAC CT License #S1-00385952
NY Hazardous Waste Transporter - NY-CT-125

ABSOLUTE TANK REMOVAL, LLC

81 Munson Street, Milford, Connecticut 06460

Office (203) 882-9391

Fax (203) 882-9392

July 28, 2005

John Byrne
415 Old Post Road
Fairfield, CT 06824

**RE: Underground Storage Tank Removal
John Byrne, 415 Old Post Road, Fairfield, CT 06824**

Dear John:

Absolute Tank Removal (ATR) removed a 1,000-gallon fuel oil underground storage tank (UST) from the above referenced site on May 12, 2005. The project foreman inspected the UST and the excavation for evidence of a release and no visual or olfactory impacts were noted.

For confirmation purposes, a discrete soil sample was collected from the approximated center of the floor of the excavation and submitted to a State certified laboratory for analysis of total petroleum hydrocarbons (TPH) by EPA method 418.1. The results of the soil sample laboratory analysis indicated a TPH concentration of ND<50 parts per million (ppm) which is below current State guidelines as outlined in the Connecticut Department of Environmental Protection's "Guidance for Residential Underground Fuel Tank Releases" dated September 2001. A copy of the laboratory report has been attached for your records.

The scope of work outlined in ATR's proposal #TR05115 has been completed. The appropriate UST removal forms will be filed with the Fire Marshal's office. If you should have any questions or require additional information, please contact me at (203) 882-9391.

Sincerely,
Absolute Tank Removal

Edward F. Marin

Edward F. Marin
Project Coordinator

EFM/tan

WIEGMASTER CERTIFICATE
RUCK SCALE

TICKET #: TCQ276



Purchased From: ABS005
ABSOLUTE TANK REMOVAL LLC
31 MUNSON STREET
MILFORD

MTLM - BIXON

CT 06460

h # ABSOLUTEBLU ID # ABSOLUTEBLU

Vendor SQ

IPMNT# COMMODITY	GROSS	TARE	NET	ADJ REASON	PD WT
TCQ276 MIXED LOAD TO BE GRADED	11300	8500			2800

ALL WEIGHTS ARE REPORTED IN POUNDS UNLESS OTHERWISE INDICATED. ALL NON-POUND WEIGHTS ARE ASSUMED TO BE MANUAL WEIGHTS
The list of prohibited materials is posted at the entrance of all MTLM NE
facilities and is available in printed form at all of our scale rooms.

TOTALS	11300	8500	0		2800
--------	-------	------	---	--	------

WIEGMASTER SIGNATURE (JANET LORENZE) _____

GRS Date	GROSS TONS _0000
GRS Time	
TRE Date	
TRE Time	

BUYER SIGNATURE _____

Seller certifies that all refrigerant including but not limited to CFC's and HCFC's
defined in section 608 of the Clean Air Act that has not leaked previously have
been recovered from appliances prior to delivery. Seller further certifies he will remove PCB capacitors,
mercury switches, fluids and any other material listed on Receiver's list of prohibited scrap.



80 Lupes Drive
Stratford, CT 06615

Tel: (203) 377-9984
Fax: (203) 377-9952
e-mail: cet@cetlabs.com

May 16, 2005

Mr. Ed Marin
Absolute Tank Removal
81 Munson Street
Milford, Ct 06460

Project: Bryne, 415 Old Post Rd, Fairfield
Project #: TR05115
CET #: 05050446
Soil: Tank Pit
Collection Date(s): 5/12/05

ANALYSIS:

Total Petroleum Hydrocarbons [EPA 418.1] Units: mg/kg Analysis Date: 5/13/05

	Tank Pit
Total Petroleum Hydrocarbons	ND < 50

As per State of Connecticut Remediation Standard Regulation, January 1996, the Residential Criteria for TPH contamination is 500 ppm.

Sincerely,

David Ditta
Laboratory Director

NOTES:

[] Indicates Date Prep Test Completed; ND is Not Detected.

Connecticut Laboratory Certification PH 0116
Massachusetts Laboratory Certification M-CT903
Rhode Island Laboratory Certification 199



**80 Lupes Drive
Stratford, CT 06615
Tel (203) 377-9984
Fax (203) 377-9952**

COMPLETE ENVIRONMENTAL TESTING, INC.

[illegible]