

WESTPORT FIRE DEPARTMENT
515 Post Road East
Westport, CT 06880

6/11/04
11:30

OFFICE OF THE FIRE MARSHAL

(203) 341-5020
FAX (203) 341-5009

REMOVAL OR ABANDONMENT OF UNDERGROUND STORAGE TANKS

1. Address/Location 5 Drumlin Rd Westport
2. Property/Name/Owner J Resnick (Mazzone)
3. Applicant's Name Frank Shook Tel. No. 203 298-6613
4. Applicant's Address 24 Codfish Hill Bethel, Ct.
5. If actual removal/abandonment is by a different company, give name, address & tel. no. of company _____
6. On back of page or attached sheet, show location(s) and size(s) of tank(s) to be removed/abandoned.
7. Who is to clean tank(s)? EGR Environmental.
8. If abandoned in place, indicate product tank filled with: _____
9. The work area perimeter shall be secured at all times.
10. **NOTIFY THE FIRE MARSHAL'S OFFICE (341-5020) AT LEAST 48 HOURS IN ADVANCE OF REMOVAL.** Inspectors are available Monday thru Friday, 8:30 AM to 4:30 PM.
11. Notify "Call Before You Dig" at 1-800-822-4455 before starting job.
12. Supply homeowner with a certified report on soil test with copy to DEP and the Westport Fire Marshal's Office.
13. All procedures as promulgated by C.G.S. 29-320 thru 29-324 including but not limited to NFPA 30 & 327 along with the regulations of any other state or federal agency shall be adhered to.

Frank Shook
Applicant's Signature


6/8/04
Date

FOR FIRE MARSHAL'S OFFICE

275 GAL UST REMOVED. TANK VISUALLY
INTACT w/ NO SIGNS OF STAINING. TANK
GRAVE VISUALLY CLEAR. SOIL SAMPLES TAKEN
BY CONTRACTOR FOR TPH ANALYSIS

task

550 gal. tank



Drumlin Rd.

PO Box 1567
New Milford, CT 06776
860/355 8773 TEL.
860/350 2258 FAX
www.gohydro.com

CT DPH LAB #PH-0627
EPA LAB #CT00051
Water, Wastewater
Soil and Air Testing
Sampling and Consulting

HYDRO
Technologies INC.
Report of Analysis

Name: Frank Shook
74 Codfish Hill
Bethel, CT 06801
Date: 6/11/2004
Receipt Date: 6/14/2004
Report Date: 6/15/2004
Site: 5 Drumline Road, Westport

Sample ID#: 74704
Sample Type: Waste/Soil
Sample Source: Tank Grave Excavation
Sampler: F. Shook

Parameter	Sample Result	Units	Limits
Organic Compounds Total Petroleum Hydrocarbons	ND	mg/kg	500

ND = Not Detected
* = Above Specified Limit

Results Certified by Hydro Technologies, Inc.

[Signature]

Note: The test results are only valid for date sample was taken. We do not accept any liability for use of these results.