

Other Options

[Return to menu](#)
[Plot this site in State Library Digital Atlas](#)
[Plot this site in Google Maps](#)

Section 7: Well Test Data

Total Depth: 45
Static Water Level: 11.5
Water Temperature:

Air Test *

100 gpm with drill stem set at 45 feet for 1 hours.
 Time of recovery 0.08 hours.
 Recovery water level 11.5 feet.
 Pumping water level feet.

** During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.*

Section 8: Remarks

Section 9: Well Log

Geologic Source

Unassigned

[illegible]

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name: PAUL STEINMETZ

Company: AAQUA DRILLING INC

License No: WWC-542

Date Completed: 11/7/2023

Section 1: Well Owner(s)

1) LORENZ CONSTRUCTION (MAIL)
2050 BROADWATER AVE, STE B
BILLINGS MT 59102 [11/07/2023]
2) LORENZ CONSTRUCTION (WELL)
48TH ST WEST & NEIBAUER RD
BILLINGS MT 59106 [11/07/2023]
3) MARSICH INVESTMENTS (MAIL)
2050 BROADWATER AVE, STE B
BILLINGS MT 59102 [11/07/2023]
4) MARSICH INVESTMENTS (WELL)
48TH ST WEST & NEIBAUER RD
BILLINGS MT 59106 [11/07/2023]

Section 2: Location

Township	Range	Section	Quarter Sections
01S	25E	28	SE¼ NE¼ NE¼
County			Geocode

YELLOWSTONE

Latitude	Longitude	Geomethod	Datum
45.724317	-108.638867	NAV-GPS	WGS84
Ground Surface Altitude	Ground Surface Method	Datum	Date

Addition	Block	Lot
SERENITY		1

Section 3: Proposed Use of Water

DOMESTIC (1)

Section 4: Type of Work

Drilling Method: ROTARY
Status: NEW WELL

Section 5: Well Completion Date

Date well completed: Tuesday, November 7, 2023

Section 6: Well Construction Details

Borehole dimensions

From	To	Diameter
0	29	8.8
29	45	7.6

Casing

From	To	Diameter	Wall Thickness	Pressure Rating	Joint	Type
-1.5	36.5	6	0.25		WELDED	A53B STEEL

Completion (Perf/Screen)

From	To	Diameter	# of Openings	Size of Openings	Description
35	45	5		.040	SCREEN-CONTINUOUS-STAINLESS

Annular Space (Seal/Grout/Packer)

From	To	Description	Cont. Fed?
0	25	BENTONITE	