

OPERATIONS PERMIT

Name: (owner) LARRY JENKINS ☒ New Installation ☒ Septic Tank
Property Location: SR# 1407 ☐ Repairs ☒ Nitrification Line
Subdivision POD PARTNERS Lot # 14
TAX ID# _____ Quadrant # _____
Contractor: ODELL JOHNSON Registration # _____
Basement with Plumbing: ☐ Garage: ☐
Water Supply: ☐ Well ☒ Public ☐ Community
Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☒ Conventional ☐ Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface No. of exact length width of depth of
Drainage Field ditches 3 of each ditch 115' ft. ditches 3 ft. ditches 18-36 in.
French Drain: — Linear feet

Date: 8-22-96

PERMIT NO. 10264

Inspected by: James E. Martin
Environmental Health Specialist

- *Septic Tank
IN wrong place
- *Septic Lines too deep,
but check out d.i.
- *Layout wrong should
have been done differently

