

## STATE OF TEXAS WELL REPORT for Tracking #501575

Owner:	<b>STUART ALKIRE/ALKIRE CONST./GLASS WELL SERV. JOB</b>	Owner Well #:	<b>No Data</b>
Address:	<b>P. O. BOX 1609 DRIPPING SPRINGS, TX 78620</b>	Grid #:	<b>57-47-8</b>
Well Location:	<b>8151 WEST FITZHUGH RD. DRIPPING SPRINGS, TX 78620</b>	Latitude:	<b>30° 16' 20.88" N</b>
Well County:	<b>Hays</b>	Longitude:	<b>098° 11' 25.44" W</b>
		Elevation:	<b>No Data</b>
Type of Work:	<b>New Well</b>	Proposed Use:	<b>Domestic</b>

Drilling Start Date: **12/20/2018**      Drilling End Date: **12/20/2018**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	<b>9</b>	<b>0</b>	<b>100</b>
	<b>6.125</b>	<b>100</b>	<b>340</b>

Drilling Method: **Air Rotary**

Borehole Completion: **Straight Wall**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks &amp; material)</i>
Annular Seal Data:	<b>0</b>	<b>100</b>	<b>Cement 14 Bags/Sacks</b>
	<b>0</b>	<b>100</b>	<b>QUICK GEL 2 Bags/Sacks</b>

Seal Method: **Pressure**

Sealed By: **Driller**

Distance to Property Line (ft.): **100+**

Distance to Septic Field or other  
concentrated contamination (ft.): **N/A**

Distance to Septic Tank (ft.): **N/A**

Method of Verification: **OWNER**

Surface Completion: **Surface Sleeve Installed**

**Surface Completion by Driller**

Water Level: **191 ft. below land surface on 2018-12-20**      Measurement Method: **Electric Line**

Packers: **Rubber at 100 ft.  
BURLAP & PLASTIC at 120 ft.  
BURLAP & PLASTIC at 220 ft.  
BURLAP & PLASTIC at 250 ft.**

Type of Pump: **Submersible**

Well Tests: **Jetted**      **Yield: 20 GPM**

Water Quality:

<i>Strata Depth (ft.)</i>	<i>Water Type</i>
<b>250 - 330</b>	<b>MIDDLE TRINITY</b>

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which  
contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **Centex Pump & Supply, Inc.**  
**2520 Hwy. 290 West**  
**Dripping Springs, TX 78620**

Driller Name: **MARTIN DALE LINGLE**

License Number: **54813**

Comments: **No Data**

Lithology:  
DESCRIPTION & COLOR OF FORMATION MATERIAL

<i>Top (ft.)</i>	<i>Bottom (ft.)</i>	<i>Description</i>
<b>0</b>	<b>1</b>	<b>ROCK</b>
<b>1</b>	<b>8</b>	<b>BROWN LIMESTONE</b>
<b>8</b>	<b>12</b>	<b>BLUE LIMESTONE</b>
<b>12</b>	<b>52</b>	<b>BROWN LIMESTONE</b>
<b>52</b>	<b>180</b>	<b>GRAY LIMESTONE W/CLAY</b>
<b>180</b>	<b>210</b>	<b>GRAY/TAN LIMESTONE</b>
<b>210</b>	<b>250</b>	<b>TAN LIMESTONE</b>
<b>250</b>	<b>270</b>	<b>RED CLAY</b>
<b>270</b>	<b>330</b>	<b>BROWN LIMESTONE</b>
<b>330</b>	<b>340</b>	<b>CLAY</b>

Casing:  
BLANK PIPE & WELL SCREEN DATA

<i>Dia (in.)</i>	<i>Type</i>	<i>Material</i>	<i>Sch./Gage</i>	<i>Top (ft.)</i>	<i>Bottom (ft.)</i>
<b>5</b>	<b>Blank</b>	<b>New Plastic (PVC)</b>	<b>SDR17</b>	<b>2</b>	<b>250</b>
<b>5</b>	<b>Perforated or Slotted</b>	<b>New Plastic (PVC)</b>	<b>SDR17 0.032</b>	<b>250</b>	<b>330</b>
<b>5</b>	<b>Blank</b>	<b>New Plastic (PVC)</b>	<b>SDR17</b>	<b>330</b>	<b>340</b>

---

**IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY**

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

**Texas Department of Licensing and Regulation**  
**P.O. Box 12157**  
**Austin, TX 78711**  
**(512) 334-5540**