



Dwayn Boos
On-Site Sewage Facilities
101 W. Main St, Mail Unit #9
Fredericksburg, TX 78624

Notice of Approval of
On-Site Sewage Facility

*Scanned
06/17/24*

Tim & Errica Henke
PO Box 1732
Fredericksburg, Tx 78624

PERMIT #9470

Property Location: 990 Axis Circle Fredericksburg, Tx

GILLESPIE COUNTY, TEXAS

This serves to notify all persons that the on-site sewage facility owned by the above has satisfied design, construction, and installation requirements of the Texas Commission on Environmental Quality (TCEQ) and Gillespie County. This Gillespie County On-Site Sewage Facility Permit is issued for the operation of the above-identified on-site sewage facility.

ANY MODIFICATIONS TO THE STRUCTURE, SYSTEM COMPONENTS, OR CHANGES OF OWNERSHIP MAY REQUIRE A NEW PERMIT. The owner must notify this office of the aforementioned changes.

300gpd = up to 4 Bedroom < 3500 Sq. Ft. Living Area

Title 30 of the Texas Administrative Code, Chapter 285 Order Adopting Rules of Gillespie County, Texas for On-Site Sewage Facilities requires an on-going maintenance contract for an aerobic surface application OSSF.

Inspector and Gillespie County Designated Representatives:

Dwayn C Boos OS0011257

Sheryl Sutton OS0006358

6/12/24

Date



GILLESPIE COUNTY

Permit Application for On-Site Sewage Facility

(Permit application is good for 1 year from purchase date.)

Permit # 9470 Date: 5/30/24 Fee: \$375

Reason For Permit (Circle one): New Construction System Replacement System Repair

Name of Landowner: Henke, Errica & Tim
(Last Name or Entity) (First Name) (MI)

Mailing Address: P.O. Box 1732, FREDERICKSBURG, TX, 78624
(House # and Street Name/or PO Box) (City & State) (Zip Code)

Daytime Phone Number(s): 619-867-6150 Cell Number(s): 619-804-7908

***Email Mandatory er2williams@gmail.com

Physical Address/Location of new Septic System: 990 Axis Circle
(House # & Street Name)

Fredericksburg, Tx, 78264 ***GATE CODE: 3917
(City & State) (Zip Code)

Legal Description: Gillespie CAD Property ID #: 179704 Volume Page Instrument#

Subdivision Name: Vineyard Ridge Subdivision Lot#: 46 Blk Phase Tract
or

Abstract: Survey Name and #:

Total Acreage: 2.56 Private Well Public Well (Supplier's Name):

Name & License # of person installing the Septic System: Rob Wise OS#

Email: rob@rwseptictx.com Cell #: (210) 749-3261

Information on a Single Family Residence: House Mobile Home Manufactured

Total Square Footage of Living Area: <1500 <2500 <3500 <4500 or

of bedrooms 3, # of bathrooms (Full) 2 (Half) . Does it have or will it have water saving devices such as low flush toilets, reduced flow shower heads or faucets, pressure reducing valves and/or faucet aerators: or N Water Softener (Demand Initiated Regeneration): Y or N
Is the water softener plumbed separate from the OSSF: Y or N

Information on a Non-Single Family Residence or Commercial/Institutional Facility (including Multi-Family residences) Describe usage:

I certify that the above statements are true and correct to the best of my knowledge. Authorization is hereby given to Gillespie County OSSF Department to enter upon the above described property for the purpose of soil/site evaluation and investigation of an on-site sewage facility.

[Signature] 05/21/24
(Signature of Landowner) (Date)

Office Use Only:

Daily wastewater usage rate: Q= 300 (gallons/day) Q: 300 gpd = up to 4 BR < 3500

Site Evaluation

Planning Materials submitted by: Installer P.E. R.S.

Development Plans required for Subdivisions, Manufactured Housing Communities, Multi-Unit Residential Development, Business Parks, or other similar uses (i.e. B&B Rental, R.V. Park)

Floodplain and/or Development Permit # 1821-20 6/3/24 SAS

For Aerobic Treatment units and non-standard treatment (if applicable):

Affidavit to the Public

Two-year Maintenance Contract

AUTHORIZATION to CONSTRUCT

DR: Sheryl Sutton DATE: 6/3/24

Certification of Approval

Final Inspection PERMIT # 9470

Date: 6/12/21 Approved by: S. Sutton

2728

I. Sewer (House Drain) 3" Sch 40 4" Sch 40 Other: _____

Slope of sewer pipe to tank minimum of 1/8"/ft.

Cleanouts every <100' and within 5' of 90° bends

II. Treatment: Conventional Tanks Aerobic Other: _____

TANKS SIZE AND COMPARTMENTS	SERIAL#	RISERS	MANUFACTURER
1. <u>1000 3lc</u>	<u>65896</u>	<u>(Y/N)</u>	<u>Block Creek Nu Water B550</u>
2. _____	_____	Y/N	_____
3. _____	_____	Y/N	_____
4. _____	_____	Y/N	_____

III. Disposal Field: Conventional Gravel Leaching Chambers (Brand) _____


Low -Pressure Pipe Mounds Gravel-Less Pipe Pressure Emitters (drip)
 ET Beds Other: _____

Subsurface Disposal:				SQUARE FEET
LENGTH OF TRENCH	WIDTH	HEIGHT OF MEDIA	CREDIT	AREA LENGTH X CREDIT
1. _____ ft.	_____ ft.	_____ ft.	_____	_____ Sq.ft.
2. _____ ft.	_____ ft.	_____ ft.	_____	_____ Sq.ft.
3. _____ ft.	_____ ft.	_____ ft.	_____	_____ Sq.ft.

IV. Surface Disposal (Application):

Loading Rate: .064 Area Required in Sq. ft. 4688 Pro Plus #3
 Timer installed (Y/N) Area Designed in Sq. ft. 5652
 Anti-siphon Hole used (Y/N)
 Check valve used (Y/N)

V. Map of System: GPS UTM 14 R _____ **Not to Scale**



OSSF SOIL EVALUATION

Date Performed: May 29, 2024 Proposed Excavation Depth: N/A

Property Location: 990 Axis Circle Fredericksburg, TX Textural Class Determined For Drain field: IV

Name of Site Evaluator: Steven Kubena Registration Number: 050037188

Requirements:

At least two (2) soil excavations must be performed on the site, at opposite ends of the proposed disposal area. Location of soil boring or dug pits must be shown on the site drawing. For subsurface disposal, soil evaluations must be performed to a depth of at least two (2) feet below the proposed excavation depth. For surface disposal, the surface horizon must be evaluated. Describe each soil horizon and identify any restrictive features on this form. Indicate depths where features appear.

Soil Boring Number <u>1</u>					
Depth (Feet)	Textural Class	Structure (if applicable)	Drainage (Mottles) Water Table	Restrictive Horizon	Observations
0	Clay	N/A	None	Limestone Rock	Limestone Rock @ 6"
1					
2					
3	IV				
4					
5					

Soil Boring Number <u>2</u>					
Depth (Feet)	Textural Class	Structure (if applicable)	Drainage (Mottles) Water Table	Restrictive Horizon	Observations
0		SAME	AS	ABOVE	
1					
2					
3					
4					
5					

ATTACH COPY OF SITE DRAWING

Features of Site Area		
Presence of 100 year flood zone	Yes	<input checked="" type="radio"/> No
Presence of upper water shed	Yes	<input checked="" type="radio"/> No
Presence of adjacent ponds, streams, water impoundments	Yes	No
Existing or proposed water well in nearby area	<input checked="" type="radio"/> Yes	No
Organized sewage service available to lot or tract	Yes	<input checked="" type="radio"/> No

I certify that the findings of this report are based on my field observations and are accurate to the best of my ability.

Steven Kubena
Signature of Site Evaluator

5-29-24
Date

OSSF Design Notes:

990 Axis Circle
Fredericksburg, Tx 78264
2.56 ACRES

LOT IS NOT LOCATED IN THE 100 YEAR FLOOD PLAIN.

KEY NOTES:

1. Design is for a 3-bedroom single family residence. (1768 SF)
2. OSSF is located outside of the 100 year flood plain.
3. Install a 2-way cleanout in a 3" or 4" sch 40 tightline from the house to the ATU, Minimum slope 1/8 in/ft.
4. ATU is a 600 gpd.
5. Supply line to the sprinklers is purple 1" schedule 40.
6. S1 is K-Rain Proplus low angle sprinklers with #3 nozzles operating @ 40 psi, 360° pattern, 30' radius.
7. S2 & S3 are K-Rain Proplus low angle sprinklers with a #3 nozzle operating @ 40 psi, 180° pattern, 30' radius.
8. There shall be no obstructions within 10' of the sprinkler heads.
9. Audible & Visual alarms, external disconnect within site of the pump tank, pump & alarms on separate breakers and external wiring in conduit are required.
10. Timer set to spray between 12:00 AM & 5:00 AM.
11. Liquid chlorinator. —
12. Any excavations and/or exposed rock in the disposal area shall be covered with topsoil and seasonal grasses shall be seeded over the disposal area in order to minimize run-off & erosion.



Steven Kubena



Steven Kubena, R.S., S.E.
240 Sendera Crossing
La Vernia, Texas 78121
Mobile (210) 296-4778 Surefloptic@gmail.com

OSSF DESIGN

Owner: **Errica & Tim Henke**
Location: 990 Axis Circle Fredericksburg, Tx 78264
Phone: (619) 804-7908
Date: 1/16/2024

Development: **Single Family Residence w/ Water Saving Devices** Bedrooms: **3** ✓ Sq. Ft: **1768** ✓

Q: **300 gpd** Soil: **IV** R_i: **0.064 gall/ft²/day** ✓

System Type: **Aerobic/Surface Application (NuWater B-550 – 600 GPD)**

Minimum Required ATU Treatment Capacity: **500 gpd**

Trash Tank: 353 gall Aerobic Tank: 600 gpd Pump Tank: 768 gall

Supply Line: **Sch 40, 1" purple (~262')** Check Valve Required: **No**

Minimum Application Area (A): 4688 ft² (A = Q/R_i)

Sprinklers: **K-Rain Super Pro 10003-RCW**

Number	Nozzle	PSI	Pattern	Radius	Area/head	GPM/head	R _i
S1	#3	40	360°	30 ft	2826 ft ²	3.1	0.064
S2	#3	40	180°	30 ft	1413 ft ²	3.1	0.064
S3	#3	40	180°	30 ft	1413 ft ²	3.1	0.064

Overlap Area: **0 ft²** Actual Application Area: **5652 ft²** GPM: **9.3 GPM**

TDH Calculations:

$$\text{Friction Head}(H_f) = \frac{1.2(10.4397)(L)(Q)^{1.85}}{(C)^{1.85}(D)^{4.8655}} = 16.7 \text{ ft}$$

L = Length of equivalent pipe length (D) in feet

C = Hazen – Williams flow coefficient (150 for schedule 40)

Q = Flow rate, gpm

D = Internal pipe diameter, inches

Pressure Head (H_p) = 92.4 ft (2.31)(psi) Elevation Head (H_e) = 5 ft

TDH = **114.06 ft** (H_f + H_p + H_e)

Pump Requirements: **9.3 GPM @ 114.06 ft TDH** Pump Used: **Blaster Model 12EB-05 (Or Equivalent)**





Steven Kubena

- ✓ • **Timer set to spray between 12:00 AM & 5:00 AM**
- ✓ • **Liquid chlorinator**



Phone: (210) 296-4778 Email: Surefloseptic@gmail.com



X = Test Holes



Steven Kubena

SITE PLAN & OSSF DESIGN

ERRICA & TIM HENKE
990 AXIS CIRCLE
Fredericksburg, Tx 78264

Steven Kubena, R.S
240 Sendera Xing
La Vernia, Texas 78121
(210) 296-4778

DATE: 01/16/2024

SCALE: 1" = 60'

WASTEWATER TREATMENT FACILITY MONITORING AGREEMENT

Regulatory Authority Hallepage County
Block Creek Aerobic Services, LLC
444 A Old Hwy #9
Comfort, TX 78013
Off. (830) 995-3189
Fax. (830) 995-4051

Permit/License Number 9470
Customer Erica + Tim Henke
Site Address 990 Axis Circle
City Fredericksburg Zip 78264
Mailing Address ""
County Gillespie Map # ""
Phone 619-867-6150
Email er2williams@gmail.com

I. General: This Work for Hire Agreement (hereinafter referred to as "Agreement") is entered into by and between _____ (hereinafter referred to as "Customer") and Block Creek Aerobic Services, LLC. By this agreement, Block Creek Aerobic Services, LLC and its employees (hereinafter inclusively referred to as "Contractor") agree to render services at the site address stated above, as described herein, and the Customer agrees to fulfill his/her/their responsibilities, as described herein.

II. Effective Date:

This Agreement commences on 06/12/24 and ends on 06/12/26 for a total of two (2) years (initial agreement) or one (1) year (thereafter). If this is an initial agreement (new installation), the Customer shall notify the Contractor within two (2) business days of the system's first use to establish the date of commencement. If no notification is received by Contractor within ninety (90) days after completion of installation or where county authority mandates, the date of commencement will be the date the "License to operate" (Notice of Approval) was issued by the permitting authority. This agreement may or may not commence at the same time as any warranty period of installed equipment, but in no case shall it extend the specified warranty.

III. Termination of Agreement:

This Agreement may be terminated by either party for any reason, including for example, substantial failure of either party to perform in accordance with the terms of this Agreement, without fault or liability of the terminating party. The terminating party must provide written notice to the non-terminating party thirty (30) days prior to the termination of this Agreement. If this Agreement is terminated, Contractor will be paid at the rate of \$75.00 per hour for any work performed and for which compensation has not been received. After the deduction of all outstanding charges, any remaining monies from prepayment for services will be refunded to customer within thirty (30) days of termination of this Agreement. Either party terminating this Agreement for any reason, including non-renewal, shall notify in writing the equipment manufacturer and the appropriate regulatory agency a minimum of thirty (30) days prior to the date of such termination. Nonpayment of any kind shall be considered breach of contract and a termination of contract.

IV. Services:

Contractor will:

- a. Inspect and perform routine upkeep on the On-Site Sewage Facility (hereinafter referred to as OSSF) as recommended by the treatment system manufacturer, and required by state and/or local regulation, for a total of three visits to site per year. The list of items checked at each visit shall be the: control panel, Electrical circuits, timer, Aeration including compressor and diffusers, CFM/PSI measured, lids safety pans, pump, compressor, sludge levels, and anything else required as per the manufacturer.
- b. Provide a written record of visits to the site by means of an inspection tag attached to or contained in the control panel.
- c. Repair or replace, if Contractor has the necessary materials at site, any component of the OSSF found to be failing or inoperative during the course of a routine monitoring visit. If such services are not covered by warranty, and the service(s) cost less than \$100.00, Customer hereby authorizes Contractor to perform the service(s) and bill Customer for said service(s). When service costs are greater than \$100.00, or if contractor does not have the necessary supplies at the site, Contractor will notify Customer of the required service(s) and the associated cost(s). Customer must notify Contractor of arrangements to affect repair of system within two (2) business days after said notification.
- d. Provide sample collection and laboratory testing of TSS and BOD on a yearly basis (commercial systems only).
- e. Forward copies of this Agreement and all reports to the regulatory agency and the Customer.
- f. Visit site in response to Customer's request for unscheduled services within forty-eight (48) hours of the date of notification (weekends and holidays excluded) of said request. Unless otherwise covered by warranty, costs for such unscheduled responses will be billed to Customer.

V. Disinfection:

TH EMH

RC

Customer's Initials



Contractor's Initials

Not required; required. The responsibility to maintain the disinfection device(s) and provide any necessary chemicals is that of the Customer.

VI. Electronic Monitoring:

Electronic Monitoring is not included in this Agreement.

VII. Performance of Agreement:

Commencement of performance by Contractor under this Agreement is contingent on the following conditions:

a. If this is an initial Agreement (new installation):

1. Contractor's receipt of a fully executed original copy or facsimile of this agreement and all documentation requested by Contractor.

If the above conditions are not met, Contractor is not obligated to perform any portion of this Agreement.

VIII. Customer's Responsibilities:

The customer is responsible for each and all of the following:

a. Provide all necessary yard or lawn maintenance and removal of all obstacles, including but not limited to dogs and other animals, vehicles, trees, brush, trash, or debris, as needed to allow the OSSF to function properly, and to allow Contractor safe and easy access to all parts of the OSSF.

b. Protect equipment from physical damage including but not limited to that damage caused by insects.

c. Maintain a current license to operate, and abide by the conditions and limitations of that license, and all requirements for and OSSF from the State and/or local regulatory agency, whichever requirements are more stringent, as well as the proprietary system's manufacturer recommendations.

d. Notify Contractor immediately of any and all alarms, and/or any and all problems with, including failure of, the OSSF.

e. Provide, upon request by Contractor, water usage records for the OSSF so that the Contractor can perform a proper evaluation of the performance of the OSSF.

f. Allow for samples at both the inlet and outlet of the OSSF to be obtained by Contractor for the purpose of evaluating the OSSF's performance. If these samples are taken to a laboratory for testing, with the exception of the service provided under Section IV (d) above, Customer agrees to pay Contractor for the sample collection and transportation, portal to portal, at a rate of \$35.00 per hour, plus the associated fees for laboratory testing.

g. Prevent the backwash or flushing of water treatment or conditioning equipment from entering the OSSF.

h. Prevent the condensation from air conditioning or refrigeration units, or the drains of icemakers, from hydraulically overloading the aerobic treatment units. Drain lines may discharge into the surface application pump tank if approved by system designer.

i. Provide for pumping and cleaning of tanks and treatment units, when and as recommended by Contractor, at Customer's expense.

j. Maintain site drainage to prevent adverse effects on the OSSF.

k. Pay promptly and fully, all Contractor's fees, bills, or invoices as described herein.

IX. Access by Contractor:

Contractor is hereby granted an easement to the OSSF for the purpose of performing services described herein. Contractor may enter the property during Contractor's normal business hours and/or other reasonable hours without prior notice to Customer to perform the Services and/or repairs described herein. Contractor shall have access to the OSSF electrical and physical components. Tanks and treatment units shall be accessible by means of man ways, or risers and removable covers, for the purpose of evaluation as required by State and/or local rules and the proprietary system manufacturer. It is Customer's responsibility to keep lids exposed and accessible at all times.

X. Limit of Liability:

Contractor shall not be held liable for any incidental, consequential, or special damages, or for economic loss due to expense, or for loss of profits or income, or loss of use to Customer, whether in contract tort or any other theory. In no event shall Contractor be liable in an amount exceeding the total Fee for Services amount paid by Customer under this Agreement.

XI. Indemnification:

Customer (whether one or more) shall and does hereby agree to indemnify, hold harmless and defend Contractor and each of its successors, assigns, heirs, legal representatives, devisees, employees, agents and/or counsel (collectively "Indemnitees") from and against any and all liabilities, claims, damages, losses, liens, causes of action, suits, fines, judgments and other expenses (including, but not limited to, attorneys' fees and expenses and costs of investigation), of any kind, nature or description, (hereinafter collectively referred to as "Liabilities") arising out of, caused by, or resulting, in whole or in part, from this Agreement.

TH EPH _____

RC



Customer's Initials

Contractor's Initials

THIS INDEMNIFICATION APPLIES EVEN IF SUCH LIABILITIES ARE CAUSED BY THE CONCURRENT OR CONTRIBUTORY NEGLIGENCE OR BY THE STRICT LIABILITY OF ANY INDEMNITEE.

Customer hereby waives its right of recourse as to any Indemnitee when Indemnification applies, and Customer shall require its insurer(s) to waive its/their right of subrogation to the extent such action is required to render such waiver of subrogation effective. Customer shall be subrogated to Indemnitees with respect to all rights Indemnitees may have against third parties with respect to matters as to which Customer provides indemnity and/or defense to Indemnitees. No Indemnification is provided to Indemnitees when the liability or loss results from (1) the sole responsibility of such Indemnitee; or, (2) the willful misconduct of such Indemnitee. Upon irrevocable acceptance of this Indemnification obligation, Customer, in its sole discretion, shall select and pay counsel to defend Indemnitees of and from any action that is subject to this Indemnification provision. Indemnitees hereby covenant not to compromise or settle any claim or cause of action for which Customer has provided Indemnification without the consent of Customer.

XII. Severability:

If any provision of the "Proposal and Contract" shall be held to be invalid or unenforceable for any reason, the remaining provisions shall continue to be valid and enforceable. If a court finds that any provision of the "Agreement" is invalid or unenforceable, but that by limiting such provision it would become valid and enforceable, then such provision shall be deemed to be written, construed, and enforced as so limited.

XIII. Fee for Services:

The Fee for Services does not include any fees for equipment, material, labor necessary for non-warranty repairs, unscheduled inspections, or Customer requested visits to the site.

XIV. Payment:


Full payment is due upon execution of this Agreement (Required of new Customer). For any other service(s) or repair(s) provided by Contractor the Customer shall pay the invoice(s) for said service(s) or repair(s) within thirty (30) days of the invoice date. The Contractor shall mail all invoices on the date of invoice. All payments not received within thirty (30) days from the invoice date will be subject to a \$29.00 late penalty and a 1.5% per month carrying charge, as well as any reasonable attorney's fees, and all collection and court costs incurred by Contractor in collection of unpaid debt(s). Contractor may terminate contract at any time for nonpayment for services. Any check returned to Contractor for any reason will be assessed a \$30.00 return check fee.

XV. Application or Transfer of payment:

The fees paid for this agreement may be transferred to subsequent property owner(s); however, this Agreement is not transferable. Customer shall advise the subsequent property owner(s) of the State requirement that they sign a replacement agreement authorizing Contractor to perform the herein described Services, and accepting Customer's Responsibilities. This replacement Agreement must be signed and received in Contractor's offices within ten (10) business days of date of transfer of property ownership. Contractor will apply all funds received from Customer first to any past due obligation arising from this Agreement including late fees or penalties, return check fees, and/or charges for services or repairs not paid within thirty (30) days of invoice date. Any remaining monies shall be applied to the funding of the replacement Agreement. The consumption of funds in this manner may cause a reduction in the termination date of effective coverage per this Agreement. See Section IV.

XVI. Entire Agreement:

This agreement contains the entire Agreement of the parties, and there are no other conditions in any other agreement, oral or written.



Rudy Carson

Block Creek Aerobic Services, LLC,
Contractor
MP# 0002036



Customer Signature

05/21/24

Date

TK EMH

Customer's Initials



RC

Contractor's Initials



TIMOTHY + ERICA HENKE
Legibly Print Landoner Name
Permit 9470
COUNTY OF GILLESPIE

TO THE PUBLIC

AFFIDAVIT

§

THE STATE OF TEXAS

§

CERTIFICATION OF ON-SITE SEWAGE FACILITY REQUIRING MAINTENANCE

According to Texas Commission on Environmental Quality (TCEQ) Rules for On-Site Sewage Facilities, this document is filed in the Deed Records of Gillespie County, Texas.

I

The Texas Health and Safety Code, Chapter 366 authorizes the Texas Commission on Environmental Quality (TCEQ) to regulate On-Site Sewage Facilities (OSSFs). Additionally, the Texas Water Code (TWC), § 5.012 and §5.013, gives the Commission primary responsibility for implementing the laws of the State of Texas relating to water and adopting rules necessary to carry out its powers and duties under the TWC. The Commission, under the authority of the TWC and the Texas Health and Safety Code, requires owner(s) to provide notice to the public that certain types of OSSFs are located on specific pieces of property. To achieve this notice, the Commission requires a deed recording. Additionally, the owner must provide proof of the recording to the OSSF permitting authority. This recorded affidavit is not a representation or warranty by the Commission of the suitability of this OSSF, nor does it constitute any guarantee by the Commission that the appropriate OSSF was installed.

II


An OSSF requiring a maintenance contract, according to 30 Texas Administrative Code § 285.91 (12) will be installed on the property described as: (Attached Legal Description Exhibits). Or Subdivision Name VINEYARD RIDGE
Lot # 46

The property is owned by: TIM + ERICA HENKE

This OSSF shall be covered by a continuous service policy for the first two years. After the initial two-year service policy, the owner of an aerobic treatment system for a single-family residence shall either obtain a maintenance contract within 30 days or maintain the system personally.

Upon sale or transfer of the above-described property, the permit for the OSSF shall be transferred to the buyer or new owner. A copy of the planning materials for the OSSF can be obtained from the Gillespie County Sanitation Department.

WITNESSED BY MY HAND ON THIS 29 DAY OF May, 2024.



(Owner(s) Signature(s))

THE STATE OF TEXAS §

COUNTY OF GILLESPIE §

SWORN TO AND SUBSCRIBED BEFORE ME ON THIS 29 DAY OF May, 2024.



Notary Public in and for the State of Texas

