

OWNER: EUSTACIA SANCHEZ HERNANDEZ
 LEGAL DESCRIPTION: RUST RANCHES, BLK PHASE I, LOT 44, ACRES 1.1
 ADDRESS: 408 RUST RANCH RD BLANCO, TX 78606
 PREPARED BY: THALIA RIVAS RS 5067 SCALE: 1" = 50'

THE SLOPE OF THE PIPE FROM THE BUILDING TO THE TREATMENT UNIT SHALL BE NO LESS THAN 1/8" FALL PER FOOT OF PIPE.

USE TWO WAY CLEAN OUT SCH 40 OR SDR 26 FROM BUILDING TO TREATMENT UNIT.

AREAS THAT ROCK MUST BE COVERED WITH A SUITABLE AMOUNT OF MATERIAL. AREAS THAT ARE BARE OR HAVE BEEN DISTURBED MUST BE SEEDED OR SODDED WITH A MIXTURE OF RYE AND BERMUDA GRASSES OR OTHER GRASS SPECIES PRIOR TO SYSTEM OPERATION.

THERE SHALL BE NOTHING IN THE SURFACE APPLICATION AREA WITHIN TEN FEET OF THE SPRINKLER WHICH WOULD INTERFERE WITH THE UNIFORM APPLICATION OF THE EFFLUENT.


LOCATION OF THE SPRINKLER HEAD MAY BE ADJUSTED IN FIELD TO AVOID OBSTACLES.

INSTALL / USE: 4923.4SF
 2 - 28'R @ 360 DEGREES

- LEGEND:
 X = TEST HOLES
 W = WATER LINE
 ☉ = CLEAN OUT



TR



RUST RANCH