

KENDALL COUNTY

Private On-Site Sewage Facility (OSSF) Licensed in Kendall County, Texas

Exp: 01/31/2024

Property Owner Roger & Susan Kainer Installer/Lic.# Paul Swoyer / OS0026238

Physical Location 582 Delaware Creek Road, Blanco TX 78606

No. Bedrooms 4 or Sq. Ft. of House <3500 ft² of Gal/Day 300

Application rate for surface irrigation 0.064 loading rate based on soil type N/A

Class No. IV Trench Req. Sq. Ft. 4687.5 ft² *Aerobic Type* MAXX AIR


Gallon Capacity Req. for Concrete Septic Tank 800 GPD ATU

Installed:

Length: _____ Width: _____ Sq. Ft. 4823.04 ft² Bed: _____ Trench: _____

Remarks: **Systems with a contract must be maintained every 4 months & inspection reports turned in to this office**

(Sketch below is of approximate distances, NOT TO SCALE)



This serves to notify all persons that the OSSF owned by the above has satisfied design, construction and installation requirements of TCEQ and Kendall County. This OSSF Permit is issued for the operation of the above-identified physical location.

ANY MODIFICATIONS TO THE STRUCTURE, SYSTEM COMPONENTS MAY REQUIRE A NEW PERMIT. The owner must notify this office of the aforementioned changes.

Kendall County, The Texas Department of Health, or their agents or designees, makes no representation that the OSSF herein licensed will provide satisfactory service to the premises served. It will be the licensee's responsibility to make any changes or modifications which operating experience may show to be necessary in order for the OSSF to provide satisfactory service. Septic distances meet minimum Texas Department of Health separation distances in most instances. Some renovations may be less if repaired or replaced in the same general area as the pre-existing system being renovated.

LICENSE TO OPERATE GRANTED & APPROVED:

Wesley Speer Digitally signed by Wesley Speer
Date: 2021.10.04 11:25:31 -05'00'

Wesley E. Speer/Designated Representative/OS31990 / Date