



STATE LICENSE NO. C57 432680
P.O. Box 845 • ATASCADERO, CA 93423 • PHONE 466-1271

February 24, 2009

First American Title
504 1st Street - Ste. B
Paso Robles, CA 93446

Re: 4.0 Hour Pump Test / .5 Hour Recovery
77511 Nacimiento Lake Drive - Bradley (Susan Ramos)

Date	Time	Flow Rate	Water Level
2/19/09	9:15 a.m.		129'
	9:16	50	141'
	9:17	50	141'
	9:20	50	141'
	9:30	50	141'
	9:45	50	141'
	10:15	50	141'
	10:45	50	141'
	11:15	50	141'
	12:15 p.m.	50	143'
	12:45	50	143'
	1:15	50	143'

RECOVERY DATA

Date	Time	Water Level
2/19/09	1:16 p.m.	143'
	1:19	133'
	1:24	131'
	1:26	131'
	1:31	131'
	1:46	131'

Please contact our office at (805) 466-1271 with any questions regarding the information provided in this letter.

Thank you,

A handwritten signature in black ink that reads 'Ned M. Thompson'.

Ned M. Thompson
NMT/kf