117 Elmont Street

IMPROVEMENTS & UPDATES

- New carpet in upstairs bedroom
- Basement mold remediation and air duct cleaning by Bactronix
- Damaged mortar at the bottom of the brick posts repaired and loose bricks re-mortared
- Stairs/brick wall brick was removed and relayed with new mortar; crumbling concrete removed; cracks/gaps patched
- Ungrounded receptacle replaced with GFCI outlet
- Sink drain stopper reattached

