



○	SINGLE RECEPTACLE	○	SINGLE FLOOD - SOFFIT MOUNTED
○ <sub>220V</sub>	SINGLE RECEPTACLE 220 VOLT	○	DOUBLE FLOOD - SOFFIT MOUNTED
○	DUPLEX RECEPTACLE	○	INCANDESCENT FIXTURE - CEILING MOUNT
○	ARC FAULT (ALL BEDROOMS)	○	WALL MOUNTED LIGHT
○	SWITCHED RECEPTACLE	○	RECESSED HIGH HAT
○	QUADRAPLEX RECEPTACLE	○	RECESSED INCAND. (EYEBALL) FIXTURE
○	SINGLE CEILING RECEPTACLE	— —	2 FEET UNDER CAB. LIGHTING
○	DUPLEX FLOOR RECEPTACLE	— —	3 FEET UNDER CAB. LIGHTING
○	SWITCHED FLOOR RECEPTACLE	— —	4 FEET UNDER CAB. LIGHTING
○	QUADAPLEX FLOOR RECEPTACLE		
GFI	GROUND FAULT INTERRUPTER		
WP	WEATHERPROOF GROUND FAULT INTERRUPTER		
EP	ELECTRICAL PANEL	— —	SINGLE POLE SWITCH
VP	VAPOR PROOF	— —	2-WAY SWITCH
□	24" X 48" FLOOR FIXTURE	— —	3-WAY SWITCH
□	12" X 48" FLOOR FIXTURE	— —	4-WAY SWITCH
○	EXHAUST FAN W/ LIGHT	— —	DIMMER SWITCH
○	EXHAUST FAN		
○	CEILING FAN	○	JUNCTION BOX
○	CEILING FAN W. LIGHT	TV	TV JACK
EM	ELECTRIC CO. METER	DATA	COMPUTER OUTLET (W/ GENERAL PURPOSE DUPLEX RECEPTACLE)
S.D.	SMOKE DETECTOR	▼	PHONE JACK
○	SINGLE POLE SWITCH	■	ELECTRIC EQUIPMENT PANEL
○	DOUBLE POLE SWITCH		

**ELECTRICAL NOTES**

- ALL ELECTRICAL WORK SHALL COMPLY WITH THE NATIONAL ELECTRICAL CODE, F.B.C. AND ALL OTHER APPLICABLE CODES. ALL WORK SHALL ALSO COMPLY WITH THE SERVING POWER AND TELEPHONE COMPANIES.
- ALL ELECTRICAL WORK TO BE DONE BY A LICENSED ELECTRICAL CONTRACTOR.
  - ALL EQUIPMENT INSTALLED OUTDOORS AND EXPOSED TO WEATHER SHALL BE WATER PROOF.
  - RECEPTALS SHALL BE INSTALLED 12" A.F.F VERTICALLY AND 12"-0" O.C. HORIZONTALLY OR AS PER LOCAL CODE REQUIREMENTS.
  - ALL RECEPTALS WITHIN 6'-0" HORIZONTAL OF A SINK, LAVATORY OR TUB SHALL BE WIRED TO A GROUND FAULT INTERRUPTED CIRCUIT.
  - WALL SWITCHES TO BE 48" A.F.F. OR AS PER LOCAL CODE REQUIREMENTS.
- OUTLETS INSTALLED OUTDOORS IN THE GARAGE AND IN ALL BATHROOMS SHALL HAVE GROUND FAULT INTERRUPTER.
- ALL SMOKE DETECTORS SHALL BE HARDWIRED (110 VOLT TYPE) TO A NON-SWITCHABLE KITCHEN OR BATHROOM LIGHTING CIRCUIT WITH BATTERY BACK-UP AND SHALL NOT BE CONNECTED ONTO THE LOAD SIZE OF GROUND FAULT CIRCUIT INTERRUPTER.
- SMOKE DETECTORS SHALL BE INSTALLED IN EACH BEDROOM AND OUTSIDE THE IMMEDIATE VICINITY OF EACH BEDROOM. ALL SMOKE DETECTORS SHALL BE INTERCONNECTED SUCH THAT THE ACTUATION OF ONE ALARM WILL ACTIVATE ALL THE ALARMS.
- A LINE VOLTAGE CARBON MONOXIDE DETECTOR SHALL BE LOCATED AT EACH LEVEL OF THE DWELLING INCLUDING THE BASEMENT OR CELLAR. IF APPLICABLE.

**ROTHE ENGINEERING, P.C.**  
 641 RT. 212 SAUGERTIES, NY 12477 PHONE: (845)246-6600 FAX: (845)246-6909

NEW RESIDENCE  
 ON LANDS OF FLIPPIN CRAZY  
 TOWN OF SAUGERTIES, COUNTY OF ULSTER



SCALE : AS NOTED

MODIFIED: 11/4/20

SHEET 10 OF 10