



10/23/2024

Building Official

Planning and Development Services

City of Canyon Lake

1117 Hidden Forest,

Canyon Lake, TX 78133

The installation of spray foam insulation along the roof deck, attic walls, exterior walls and thermal floor by Best Insulation for 1117 Hidden Forest, Canyon Lake, TX 78133, meets performance-based R-20 specifications along the sloped roof deck areas and R-13 specifications along the attic walls, exterior walls and thermal floor.

Sloped roof deck areas over livable spaces were sealed to a nominal 5.5" with SealTite Pro OCX, a 0.5 lb/ft density, open cell, spray-applied polyurethane foam with an overall R-value of 3.70 at one inch.

Attic walls were sealed with a nominal 3.5" with SealTite Pro OCX, a 0.5 lb/ft density, open cell, spray-applied polyurethane foam with an overall R-value of 3.70 at one inch.

Exterior walls were sealed with a nominal 3.5" with SealTite Pro OCX, a 0.5 lb/ft density, open cell, spray-applied polyurethane foam with an overall R-value of 3.70 at one inch.

Thermal floor areas were sealed with a nominal 3.5" with SealTite Pro OCX, a 0.5 lb/ft density, open cell, spray-applied polyurethane foam with an overall R-value of 3.70 at one inch.

SealTite Pro OCX may be left exposed in attics per testing in accordance with AC 377, Appendix X. See the attached technical data sheet and the ICC-ES Evaluation Report ESR-615 for further information.

If you have any further questions, please contact Michael Duran at 210-382-1265.

Respectfully,

Michael M. Duran

Michael M. Duran

South Texas Sales Consultant