

Brehler Electric, Inc.
 7106 Johnson Mill Rd.
 Bahama, NC 27503

Invoice

Date	Invoice #
3/23/2026	5564

Bill To
Christina Cupido 2606 Englewood Ave. Durham, NC 27705

P.O. No.	Terms	Project

Quantity	Description	Rate	Amount
7.5	2502 Englewood - Perform electrical inspection and repairs: Corrected HVAC overcurrent protection (Replaced 30A breaker with 25A per unit specifications) Repaired attic pullchain (Broken base/socket) Checked feeders (cables) supplying power to sub-panels in house (200A) and garage (100A). Breakers are properly sized for conductors feeding these panels. (#8/40A breaker to garage, #1 Aluminum/100A to household subpanel) Secured loose outlets/switches Installed new motion sensor light switch in master bath Removed/secured/terminated wiring in crawlspace: the majority of which was left over from house being rewired several years ago.	105.00	787.50T
	1 25A double pole breaker, 1 Lutron motion sensor, 1 pull-chain light fixture/bulb, 4 single-gang switch boxes/blank covers	74.69	74.69
	Durham County Sales & Use Tax	7.50%	59.07

Thank you for your business.	Total	\$921.26
------------------------------	--------------	----------