



U.S. DEPARTMENT OF ENERGY

THIS HOME'S SCORE 4 OUT OF 10

THIS HOME'S ESTIMATED ENERGY COSTS

\$2,600

PER YEAR

### HOME PROFILE

**LOCATION:**

265 NE 36th Ct  
Hillsboro, OR 97124

**YEAR BUILT:**

2019

**HEATED FLOOR AREA:**

2,594 sq.ft.

**NUMBER OF BEDROOMS:**

3

### ASSESSMENT

**ASSESSMENT DATE:**

05/28/2026

**SCORE EXPIRATION DATE:**

05/28/2034

**ASSESSOR:**

Chris Aldridge  
Inspectek West

**PHONE:**

503-201-0900

**EMAIL:**

caldridge54@gmail.com


**CCB LICENSE #:**

118865

*Flip over to learn how to improve this score and use less energy!*



### Home Energy Score



Official Assessment | ID# 654542

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at HomeEnergyScore.gov.


### HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

<b>Electric:</b> 8,649 kWh/yr (\$0.18/kWh).....	\$1,573
<b>Natural Gas:</b> 694 therms/yr (\$1.48/therm).....	\$1,027
<b>Other:</b> .....	\$0
<b>Solar Generation:</b> .....	(\$0)
<b>TOTAL ENERGY COSTS PER YEAR</b>	<b>\$2,600</b>

**How much solar energy does this home generate?**

\_\_\_\_\_ kWh/yr

### THIS HOME'S CARBON FOOTPRINT:



- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices in your area.
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- This report is valid for eight years from the assessment date. A free reprint of the report is available from [us.greenbuildingregistry.com](http://us.greenbuildingregistry.com) with updated utility and carbon information annually.
- **This report meets Oregon's Home Energy Performance Score Standard.**

Score today:

4

Score with priority improvements:

4

Estimated energy savings with priority improvements:

\$0 PER YEAR

Estimated carbon reduction with priority improvements:

0% PER YEAR

## TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- Get your home energy assessment. Done!
- Choose energy improvements from the list of recommendations below.
- Select a contractor (or two, for comparison) and obtain bids. If a new home, discuss with the builder. Checkout [www.energytrust.org/findacontractor](http://www.energytrust.org/findacontractor) or call toll free **1-866-368-7878**.
- To find out more information about the state of Oregon Home Energy score program visit: [oregon.gov/energy/home-energy-score](http://oregon.gov/energy/home-energy-score)
- Discover local incentives and learn more about Hillsboro's Home Energy Score Program at: [Hillsboro-Oregon.gov/EnergyScore](http://Hillsboro-Oregon.gov/EnergyScore)

## PRIORITY ENERGY IMPROVEMENTS <sup>1</sup>

FEATURE	TODAY'S CONDITION <sup>3</sup>	RECOMMENDED IMPROVEMENTS
---------	--------------------------------	--------------------------

## ADDITIONAL ENERGY RECOMMENDATIONS <sup>2</sup>

FEATURE	TODAY'S CONDITION <sup>3</sup>	RECOMMENDED IMPROVEMENTS
Attic insulation	Ceiling insulated to R-38	Insulate to R-38 or R-49 if code requires it
Duct sealing	Un-sealed	Reduce leakage to a maximum of 10% of total airflow
Envelope/Air sealing	Not professionally air sealed	Professionally air seal
Air Conditioner	13.0 SEER	
Cathedral Ceiling/Roof	Roof insulated to R-21	
Duct insulation	Insulated	
Floor insulation	Insulated to R-19	
Foundation wall insulation	Insulated to R-0	
Heating	Gas furnace 95% AFUE	
Knee Wall insulation	Knee wall insulated to R-11	
Wall insulation	Insulated to R-15	
Water Heater	Gas 0.63 UEF	
Windows	Double-pane, low-E glass	
Solar PV	N/A	

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. All together, these priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. Today's Condition represents the majority condition for that feature in the home. Additional energy efficient features may be present in the home and not accounted for in this report. Trees and other features may provide additional energy efficiency benefits to the building.