Hillsboro OREGON

U.S. DEPARTMENT OF ENERGY

THIS HOME'S SCORE **3** OUT OF 10

THIS HOME'S ESTIMATED **ENERGY COSTS**

$2,608

PER YEAR

HOME PROFILE

LOCATION:
3815 NE Meadow Ln
Hillsboro, OR 97124

YEAR BUILT:
1972

HEATED FLOOR AREA:
1,416 sq.ft.

NUMBER OF BEDROOMS:
4

ASSESSMENT

ASSESSMENT DATE:
10/06/2026

SCORE EXPIRATION DATE:
10/06/2034

ASSESSOR:
Chris Aldridge
Inspectek West

PHONE:
503-201-0900


EMAIL:
caldridge54@gmail.com

CCB LICENSE #:
118865

Flip over to learn how to improve this score and use less energy!

Better Buildings U.S. DEPARTMENT OF ENERGY

Home Energy Score



Official Assessment | ID# 684102

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at HomeEnergyScore.gov.


HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

Electric: 11,134 kWh/yr ($0.18/kWh)	$2,025
Natural Gas: 394 therms/yr ($1.48/therm)	$583
Other:	$0
Solar Generation:	($0)
TOTAL ENERGY COSTS PER YEAR	**$2,608**

How much solar energy does this home generate?

_____ kWh/yr

THIS HOME'S CARBON FOOTPRINT:



Carbon footprint by fuel type: Electric: 3.6 Natural Gas: 2.1

- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices in your area.
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- This report is valid for eight years from the assessment date. A free reprint of the report is available from **us.greenbuildingregistry.com** with updated utility and carbon information annually.
- **This report meets Oregon's Home Energy Performance Score Standard.**

Score **today:**	Score **with priority improvements:**	Estimated **energy savings** with priority improvements:	Estimated **carbon reduction** with priority improvements:
3	**8**	**$736** PER YEAR	**28%** PER YEAR

TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- [x] Get your home energy assessment. Done!
- [ ] Choose energy improvements from the list of recommendations below.
- [ ] Select a contractor (or two, for comparison) and obtain bids. If a new home, discuss with the builder. Checkout **www.energytrust.org/findacontractor** or call toll free **1-866-368-7878.**
- [ ] To find out more information about the state of Oregon Home Energy score program visit: **oregon.gov/energy/home-energy-score**
- [ ] Discover local incentives and learn more about Hillsboro's Home Energy Score Program at: **Hillsboro-Oregon.gov/EnergyScore**

PRIORITY ENERGY IMPROVEMENTS [1]

FEATURE	TODAY'S CONDITION[3]	RECOMMENDED IMPROVEMENTS
Air Conditioner	9.0 EER	When replacing, upgrade to ENERGY STAR
Duct sealing	Un-sealed	Reduce leakage to a maximum of 10% of total airflow
Envelope/Air sealing	Not professionally air sealed	Professionally air seal
Floor insulation	Insulated to R-0	Insulate to R-30 or fill floor cavity
Heating equipment (90%)	Gas furnace 80% AFUE	When replacing, upgrade to ENERGY STAR
Water Heater	Electric 0.95 EF	When replacing, upgrade to ENERGY STAR, (EF>=2.67 or UEF>= 2.67)

ADDITIONAL ENERGY RECOMMENDATIONS [2]

FEATURE	TODAY'S CONDITION[3]	RECOMMENDED IMPROVEMENTS
Attic insulation	Ceiling insulated to R-19	Insulate to R-38 or R-49 if code requires it
Duct insulation	Insulated	
Heating (10%)	Electric heat	
Wall insulation	Insulated to R-7	
Windows	Double-pane, low-E glass	
Solar PV	N/A	

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. All together, these priority improvements have a simple payback of ten years or less.
2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.
3. Today's Condition represents the majority condition for that feature in the home. Additional energy efficient features may be present in the home and not accounted for in this report. Trees and other features may provide additional energy efficiency benefits to the building.