



U.S. DEPARTMENT OF ENERGY

THIS HOME'S SCORE 1 OUT OF 10

THIS HOME'S ESTIMATED ENERGY COSTS

\$4,511

PER YEAR

HOME PROFILE

LOCATION:

4254 SE Bentley St
Hillsboro, OR 97123

YEAR BUILT:

1965

HEATED FLOOR AREA:

940 sq.ft.

NUMBER OF BEDROOMS:

2

ASSESSMENT

ASSESSMENT DATE:

06/08/2026

SCORE EXPIRATION DATE:

06/08/2034

ASSESSOR:

Andy Shupp
Shupp Home Energy Scores

PHONE:

5034908964

EMAIL:

andy@
shupphomeenergyscores.com


CCB LICENSE #:

240857

Flip over to learn how to improve this score and use less energy!



Home Energy Score



Official Assessment | ID# 656545

The Home Energy Score is a national rating System developed by the U.S. Department of Energy. The Score reflects the estimated energy use of a home based upon the home's structure and heating, cooling, and hot water systems. The average score is a 5. Learn more at HomeEnergyScore.gov.


HOW MUCH ENERGY IS THIS HOME LIKELY TO USE?

Electric: 24,802 kWh/yr (\$0.18/kWh).....	\$4,511
Natural Gas: 0 therms/yr (\$1.48/therm).....	\$0
Other:	\$0
Solar Generation:	(\$0)
TOTAL ENERGY COSTS PER YEAR	\$4,511

How much solar energy does this home generate?

_____ kWh/yr

THIS HOME'S CARBON FOOTPRINT:



- Actual energy use and costs may vary based on occupant behavior and other factors.
- Estimated energy costs were calculated based on current utility prices in your area.
- Carbon footprint is based only on estimated home energy use. Carbon emissions are estimated based on utility and fuel-specific emissions factors provided by the OR Department of Energy.
- This report is valid for eight years from the assessment date. A free reprint of the report is available from us.greenbuildingregistry.com with updated utility and carbon information annually.
- **This report meets Oregon's Home Energy Performance Score Standard.**

Score today:

1

Score with priority improvements:

4

Estimated energy savings with priority improvements:

\$1,880 PER YEAR

Estimated carbon reduction with priority improvements:

42% PER YEAR

TACKLE ENERGY WASTE TODAY!

Enjoy the rewards of a comfortable, energy efficient home that saves you money.

- Get your home energy assessment. Done!
- Choose energy improvements from the list of recommendations below.
- Select a contractor (or two, for comparison) and obtain bids. If a new home, discuss with the builder. Checkout www.energytrust.org/findacontractor or call toll free **1-866-368-7878**.
- To find out more information about the state of Oregon Home Energy score program visit: oregon.gov/energy/home-energy-score
- Discover local incentives and learn more about Hillsboro's Home Energy Score Program at: Hillsboro-Oregon.gov/EnergyScore

PRIORITY ENERGY IMPROVEMENTS ¹

FEATURE	TODAY'S CONDITION ³	RECOMMENDED IMPROVEMENTS
Cathedral Ceiling/Roof	Roof insulated to R-0	Insulate cathedral ceiling/roof to R-30 or maximum possible
Envelope/Air sealing	Not professionally air sealed	Professionally air seal
Wall insulation	Insulated to R-0	Fully insulate wall cavities
Windows	Single-pane	When replacing, upgrade to ENERGY STAR

ADDITIONAL ENERGY RECOMMENDATIONS ²

FEATURE	TODAY'S CONDITION ³	RECOMMENDED IMPROVEMENTS
Foundation wall insulation	Insulated to R-0	
Heating	Electric heat	
Water Heater	Electric 0.92 EF	
Solar PV	N/A	

1. To achieve the "Score with Priority Improvements" all recommended improvements in the Priority Energy Improvements section must be completed. All together, these priority improvements have a simple payback of ten years or less.

2. Additional energy efficiency improvements may take longer than ten years to make a return on investment but can have a significant impact on the comfort, efficiency and environmental impact of your home.

3. Today's Condition represents the majority condition for that feature in the home. Additional energy efficient features may be present in the home and not accounted for in this report. Trees and other features may provide additional energy efficiency benefits to the building.